

KATALOG APAR COMMANDO



(HEAD OFFICE) PT SINERGI TRIJAYA SAFETINDO
 Jl. KH. Hasyim Ashari No.58, RT.002/RW.011, Pedurenan,
 Kec. Karang Tengah, Kota Tangerang, Banten 15157

www.aparsni.com | www.sinergisafety.co.id

COMMANDO

APAR POWDER

2KG

Free
Wall Hanger



Tersertifikasi

SNI

180-1:2022

APAR POWDER 2KG

SPEKIFIKASI

Fire Rating	: 8A / 34B
Tekanan Kerja	: 15 Bar
Berat N.W	: 3.475 Kg
Berat Isi	: 2Kg +/- 3%
Lebar Diameter	: 11 cm
Tinggi	: 37 cm
Jarak Semperot	: 2-7 Meter
Gas Pendorong	: N2

Kelas Api



COMMANDO

APAR FOAM AFF 3KG

Free
Wall Hanger



Tersertifikasi

SNI

180-1:2022

APAR FOAM AFF **3KG**

SPEKIFIKASI

Fire Rating	: 5A / 21B
Tekanan Kerja	: 15 Bar
Berat N.W	: 5.12 Kg
Berat Isi	: 3Kg +/- 3%
Lebar Diameter	: 12.5 cm
Tinggi	: 45 cm
Jarak Semperot	: 2-7 Meter
Gas Pendorong	: N2

Kelas Api



COMMANDO

APAR POWDER

4KG

Free
Wall Hanger



Tersertifikasi




180-1:2022

APAR POWDER 4KG

SPEKIFIKASI

Fire Rating	: 13A / 70B
Tekanan Kerja	: 15 Bar
Berat N.W	: 6.25 Kg
Berat Isi	: 4Kg +/- 3%
Lebar Diameter	: 13 cm
Tinggi	: 49 cm
Jarak Semperot	: 2-7 Meter
Gas Pendorong	: N2

Kelas Api



APAR CLEAN AGENT 3KG

SPEKIFIKASI

Fire Rating	: 5A / 21B
Tekanan Kerja	: 15 Bar
Berat N.W	: 5.1 Kg
Berat Isi	: 3Kg +/- 3%
Lebar Diameter	: 12.5 cm
Tinggi	: 45 cm
Jarak Semperot	: 2-7 Meter
Gas Pendorong	: N2

Kelas Api

